

Questions:

1. Will there be blasting allowed to install the proposed sanitary sewer?
2. Will extra material from the excavation be required to be hauled off site?

Answer:

1. There is not any restriction in the plans to preclude blasting. The bidders are directed to APWA Section 2505.7 for more specific guidance regarding blasting. Kansas City, Missouri is the governing agency. All requirements within the City Limits will be applicable.
2. Bidders are directed to APWA Section 2101.3 F. (Disposal of Materials) **No waste is anticipated.**

Courtney Allison

Administrative Assistant

Wilson & Company, Inc., Engineers & Architects

903 East 104th Street, Suite 210

Kansas City, MO 64131

816-701-3100 direct 816-942-3013 fax

www.wilsonco.com